# CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
# OFFICE OF THE STATE FIRE MARSHAL
# FIRE ENGINEERING & INVESTIGATIONS DIVISION
# BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

| | |
|---|---|
| **LISTING No.:** | 8170-2444:0001 |
| **CATEGORY:** | 8170 - IGNITION-RESISTANT MATERIALS |
| **LISTEE:** | GTO Aluminum USA 4731 West Post Road, Suite #130, Las Vegas, NV, 89118<br>Contact: Yaffe, Oren 702-881-7608<br>Email: oren@gtoaluminum.com |
| **DESIGN:** | Universal 140 Aluminum Siding material. Products come in planks 0.059" thick by 7" wide.<br><br>Refer to manufacturer's installation instructions and product data sheets for additional detailed product description and construction. |
| **RATING:** | Ignition Resistant<br><br>Flame Spread Index: 0<br><br>Smoke Developed Index: 25<br><br>Maximum Flame Front: <10.5 feet<br><br>Tested in accordance with ASTM E2768-11 (ASTM E84 with an additional 20-minute period) |
| **INSTALLATION:** | In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction. |
| **MARKING:** | Listee name, Model number, rating and SFM label. |
| **APPROVAL:** | Listed as an ignition resistant material in accordance with Section 503.2.4 of the 2025 California Wildland-Urban Interface. Refer to listee's Installation Instruction Manual for details. Model was tested in accordance with ASTM E2768-11 with a 30-minute total test duration. |
| **NOTES:** | |

10-23-26 MH



**Listing Expires: 06/30/2027**

# CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
# OFFICE OF THE STATE FIRE MARSHAL
# FIRE ENGINEERING & INVESTIGATIONS DIVISION
# BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 10/27/2026**

Authorized By: **Michael Huang**, Program Coordinator
Fire Engineering & Investigations Division



**Listing Expires: 06/30/2027**